

TEMPORARY PERMIT APPLICATION STRUCTURES IN A COMMERCIAL OR INDUSTRIAL USE (665)

City of Okeechobee - General Services Department

55 SE 3rd Ave, Room 101, City Hall, Okeechobee, FL 34974

Phone: (863) 763-3372 ext. 9821

	1 110110. (0	000) 100 0012 CAL 0021		
DATE RECEIVED: DATE ISSUED:				
APPLICATION NO.:		EVENT DATE(S) & TIME:		
FEE: \$175.00		DATE PAID:		
Name of Property Owner(s):				
Address:				
Name of Property Owner(s): Address: Telephone Numbers:				
Home.	Work:	Cell:		
Name of Applicant:				
Address: Telephone Numbers:				
Telephone Numbers: Home:	Work:	Cell:		
,	VVOIN.			
Future Land Use Map Desigation:		Current Zoning	Designation:	
Legal Description of Property:				
Address of Property:				
Please Explain Type of Use:				
Briefly describe use of adjoining property				
North:		East:		
South: Temporary structures to a commercial	- n in al tui al n	West:	haatha an ainsilan tanan anan	
structure which is an extension of the esubject to the following regulations. The 1. Produce proof that it is the princi 2. Not erect the structure for more 3. Meet all required setbacks and olocated, and all required sign regula 4. Notarized letter of permission, if 5. Proof of liability insurance paid in	existing principal us e applicant shall: pal use applicant's than 15 days, four t ff-street parking re ations. applicant is not the	e in a commercial or inventory being sold. times a year. gulations of the distri	industrial district, and shall be	
City Staff (Please review the application, attach of	omments or special co	nditions).		
Business Tax Receipt Verification:			Date:	
Fire Department Approval:			Date:	
Police Department Approval:			Date:	
Public Works Department Approval:			Date:	
Building Inspector Approval:			Date:	
City Administrator Approval:			Date:	
I hereby certify that the information on this application is cor False or misleading information may be punishable by a fine				
Signature of Applicant			Date	



City of Okeechobee 55 SE 3rd Avenue Okeechobee, FL 34974 Phone (863) 763-3372

Okeechobee County Fire Rescue 707 NW 6th Street Okeechobee, FL 34972 Phone (863) 763-5544



Tent Permit Application

Permit #___

In addition to this permit application, three copies of the following must be submitted for approval:

☐ Certificate of Flame Resistance for tent/canopy meeting the flame propagation performance criteria per NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films

Permit is not required for tents less than 900 square feet

☐ Floor Plan of tent depicting layout, entrances/exits, and extinguisher locations (hand drawn plans will not be accepted).

□ Copy of License to sell fireworks (if applicable)					
Owner Information	Owner	Contractor Information	Owner		
Proposed Tent Location Address Parcel Identification Number		Proposed Tent Description Tent Size □ Open □ Enclosed			

The following requirements are in compliance with National Fire Protection Association (NFPA) 101 Life Safety Code, Chapter 11 Special Structures and High-Rise Buildings, NFPA 1124, Chapter 7 Retail Sales of Consumer Fireworks. These are the minimum requirements approved by the Authority Having Jurisdiction (AHJ), Okeechobee County Fire Rescue. The AHJ reserves the right to exceed the minimum requirements as conditions warrant.

Please initial next to each statement.

PORTABLE FIRE EXTINGUISHERS: Fire extinguishers must be inspected by a licensed contractor, have a current tag, and be readily accessible.

MEANS OF EGRESS: The minimum number of exits provided from the retail sales areas shall be not less than three (3). Means of egress, including but not limited to aisles, doors, and exit discharge, shall be clear at all times when the tent is occupied. Exit signs shall not be required to be illuminated in tents that are not open for business after dark. Exit openings from tents shall have a clear opening width of not less than 44 inches.

EGRESS TRAVEL DISTANCE: Exits provided for the retail sales area of tents shall be located so that the maximum egress travel distance, measured from the most remote point to an exit along the natural and unobstructed path of egress travel does not exceed 75 feet.

AISLE WIDTH: Aisles shall have a minimum clear width of 48 inches and shall be maintained and unobstructed at all times the tent is occupied by the public. EMERGENCY LIGHTING: The means of egress, including exit discharge shall be illuminated whenever the tent is occupied. Emergency lighting shall not be required in tents that are not open for business after dusk.

ELECTRICAL: Electrical wiring must be rated for exterior use and not overloaded. Where temporary electrical conductors are placed on top of an outdoor surface to connect the permanent power source to the tent's temporary electrical system, the conductors shall be provided with physical protection against damage caused by pedestrian or vehicular traffic. Temporary electrical wiring installed in tents shall comply with NFPA 70, National Electric Code.

FIRE DEPARTMENT ACCESS: Any portion of the sidewall of a tent shall be accessible within 150 feet of a public way or approved access by the fire department.

COOKING OPERATIONS: Cooking requiring LPG must be outside of the tent pointing away from exposures. Cooking equipment of any type shall not be permitted within 20 feet of tents used for storage or sale of consumer fireworks. Open flame cooking equipment of any type shall not be allowed within 50 feet of tents used for storage or sale of consumer fireworks.

SIGNS: Signage stating "NO SMOKING" in 2-inch letters on a contrasting background shall be conspicuously posted at each entrance.

SECURITY: Signage stating "NO FIREWORKS DISCHARGE WITHIN 300 FEET" in 4-inch letters on a contrasting background shall be conspicuously posted (if applicable).

FLAME BREAKS: Tents used for storage or sale of consumer fireworks shall not exceed display dimensions of 4 feet wide, 8 feet in length and 6 feet in height. Flame breaks and solid display surfaces shall not be required for packaged fireworks merchandise displayed in bins, display racks, on pallets or tables located at the end of a row of display fixtures.

CLEARANCE TO COMBUSTIBLES: The area located within 30 feet of a tent used for sales of consumer fireworks shall be kept free of accumulated dry grass, dry brush, and combustible debris.

DISTANCE FROM FUEL DISPENSING: Tents for use of consumer fireworks sales shall not be located within 50 feet from the following: retail propane-dispensing station dispensers; aboveground storage tanks for flammable or combustible liquid, flammable gas, or flammable liquified gas; compressed natural gas-dispensing station dispensers; motor vehicle fuel-dispensing station dispensers.

DISTANCE FROM BULK FUEL DISPENSING: Tents for use of consumer fireworks sales shall not be located within 300 feet of any aboveground bulk storage or bulk dispensing area for the following: flammable or combustible liquid, flammable gas, flammable liquified gas.

PARKING: No motor vehicle or trailer used for the storage of consumer fireworks shall be parked within 20 feet of a tent except when delivering, loading, or unloading fireworks or other merchandise and materials used, stored, or displayed for sale.

SEPARATION DISTANCES: Tents for use of consumer fireworks sales shall have a minimum separation distance of 20 feet from building, stands, combustibles, other tents and any motor vehicle or trailer used for the storage of consumer fireworks. Tents for use of consumer fireworks shall be 10 feet from vehicle parking.

SOURCES OF IGNITION: Temporary electrical equipment, battery-powered equipment, and electrical cords that are used in conjunction with a tent used for the sales of consumer fireworks shall be listed and used in accordance with their listing.

PORTABLE GENERATORS: Portable generators supplying power to tents for the sale of consumer fireworks shall use only Class III combustible liquid fuels. Class II and Class III combustible liquid generator fuel shall be limited to not more than 5 gallons. Portable generators shall be allowed to use Class I flammable liquids as fuel, provided the quantity of such fuel is limited to 2 gallons. Portable generators shall be located not less than 20 feet from the tent. Where generator fuel storage is located not less than 50 feet from a tent for the sale of consumer fireworks.

RECORDS: A copy of the approved permit shall be on the premises and made available to the AHJ upon request.